

MPA Braunschweig, Beethovenstr. 52, 38106 Braunschweig, Germany

## Certificate of constancy of performance

0761 – CPR – 0832

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the construction product

**Fire and smoke protection doors,  
designed as lifting door in staggered door design type "MATADOOR-IV"**

produced by or for

**Jansen Tore GmbH & Co. KG  
Am Wattberg 51  
26903 Surwold  
Germany**

in the manufacturing plant

**Surwold (Germany).**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

**EN 16034:2014 in connection with EN 13241:2003+A2:2016**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product.**

This certificate has an annex with one page. It has first been issued on 2017-09-25. It will remain valid till 2022-09-24, as neither the harmonised specification, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the product certification body.

Braunschweig, 2021-01-04

Z-3/1427/17



Dr.-Ing. W. Hinrichs  
Head of certification

**Intended use and essential characteristics according to EN 13501-2:2016  
of the lifting door in staggered door design "MATADOOR-IV"**

If the room is divided into fire and/or smoke sections  
and/or in escape routes

Use of single-leaf, one-piece lifting door in staggered door design "MATADOOR-IV":

R	E	I	W		tt	-	M	C	S	IncSlow	sn	ef	r
	<b>x</b>	<b>x</b>	<b>x</b>		<b>x</b>	-		<b>x</b>	<b>x</b>				

E 15 / E 20 / E 30 / E 45 / E 60 / **E 90**

El<sub>1</sub> 15 / El<sub>1</sub> 20 / El<sub>1</sub> 30 / El<sub>1</sub> 45 / **El<sub>1</sub> 60**

El<sub>2</sub> 15 / El<sub>2</sub> 20 / El<sub>2</sub> 30 / El<sub>2</sub> 45 / El<sub>2</sub> 60 / **El<sub>2</sub> 90**

EW 20 / EW 30 / EW 60 / **EW 90**

C / C0 / C1 / **C2**

**S<sub>a</sub>**

Basis:

Classification report No.: K-2202/070/19-MPA BS of 2019-11-18

----- End of the certificate of constancy of performance -----